



# ROCKFORD FIRE DEPARTMENT INCIDENT UPDATE

## Incident Information

Business Name: Valkommen Plaza

Address of Incident: 310 7th St.

Date of Incident: 10/8/2017

Time of Incident: 16:09

Type of Incident: Residential Structure Fire

Cause of Fire: Accidental

Estimated Loss: \$20,000

## Injury Data

Civilian Injuries: 1

Civilian Deaths: 0

## Fire Department Response

Engine(s): 4

Ladder(s): 3

District Chief(s): 2

Quint(s):       

Ambulance(s): 2

Haz Mat Unit(s):       

Boat(s):       

Diver(s):       

Other(s): 1

Total Firefighters: 31

Response Time: 1 min

## Narrative

The Rockford Fire Department responded to a high rise fire at 310 7th St. The first arriving unit found a small kitchen fire on the 9th floor. The sprinkler system limited the fire damage to the kitchen area only. There was some water damage due to the sprinkler system being activated. The occupant of the apartment was transported to the hospital for some minor burns to her hands. She was expected to be released. Red Cross was assisting with relocation efforts.

For additional information contact: 779-348-7172

Prepared by: DC Tracy Renfro on 10/8/2017 at 20:18